



Ethernet Packet Generator
USER GUIDE
Version 3.2



APG4 APG8 APG208

Hardware Versions

This document applies to the following hardware versions:

| | |
|---------------------------------|--|
| <p>Version 1 (APGV1)</p> | <p>Launched: 2016 with API 161016</p> <p>Products: APG4, APG8, APG200, APG208</p> <p>Port Speeds: 1Gbps, 10Gbps, 40Gbps</p> <p>Processing Cores: 6.X (10Gbps) 7.X (1Gbps) Note: Cannot mix 10Gbps and 1Gbps ports</p> <p>Capture Buffer: 64MB/port (10G) 256MB/port (40G)</p> <p>Timestamp Resolution: 8ns</p> |
| <p>Version 2 (APGV2)</p> | <p>Launched: 2023 with API 161016</p> <p>Products: APG4V2-10, APG8V2-10</p> <p>Port Speeds: 1Gbps, 10Gbps 2.5Gbps, 5Gbps (optional)</p> <p>Processing Core: 10.X (10Gbps/1Gbps)</p> <p>Capture Buffer: 128MB/port</p> <p>Timestamp Resolution: 2.5ns</p> |

Software Versions

This document applies to the following software versions:

| | Version 1 (APGV1) | Version 2 (APGV2) |
|------------------------------|---|--|
| APG API | 161016 | 161016 |
| APG Unit Firmware | Version 2.3 | Version 1.6 |
| APG Processing Core | <p>Version 6.010E (10Gbps) Version 7.0103 (1Gbps) Datecode: 01 March 2019</p> | <p>Version 10.3 Datecode: 6 August 2024</p> |
| APG Control Interface | Version 3.4 | Version 3.4 |

Revision History

| Date | Version | Changes |
|-------------------|---------|---|
| 4 July 2016 | 0.4 | <ul style="list-style-type: none"> Restricted Customer Release Missing Linux installation information |
| 11 August 2016 | 1.0 | <ul style="list-style-type: none"> General release Added Linux Installation (Section 2.3) Modified 10GBase-T SFP limitations (Section 3.1.1) Modified Front Panel LED behaviour (Section 3.1.3.1) Added File-Save (Section 6.3.1) Added Tools-Upgrade (Section 6.3.8) |
| 3 November 2016 | 1.1 | <ul style="list-style-type: none"> Added APG200 |
| 7 June 2017 | 2.0 | <ul style="list-style-type: none"> Updated FCC statement Added Port Topology changes (Sections 3.1.2 and 5.3), including 40Gbps / 4x10Gbps support on QSFP+ interfaces. Added Burst Mode (Section 6.5.1) Added Packet/Second Mode (Section 6.5.1) Added Packet Timestamps (Section 6.5.3) Added Deep Packet Capture (Section 6.11) Added 'Save to PCAP' (Section 6.11) |
| 5 September 2017 | 2.0.2 | <ul style="list-style-type: none"> Added Capture Buffer limits (Section 5.5) Added Transmit Frame Length limits (Section 6.5.1) Modified Capture Control description (Section 6.10.3) |
| 8 February 2018 | 2.1 | <ul style="list-style-type: none"> Added Save/Load Configuration (Section 6.3.2 & 6.3.3) Local capture buffer sizes increased to 64KB (10Gbps), and 256KB (40Gbps) (Sections 5.5 & 6.11) |
| 27 January 2019 | 2.2 | <ul style="list-style-type: none"> Added 1G Topology (Section 5.3.1) Added 1Gbps SFP support Added Copper Transceiver support for SFP+/SFP ports |
| 21 February 2023 | 3.0 | <ul style="list-style-type: none"> Added Hardware Versions and extended Software Versions Added UKCA Statement Removed APG200, added APGV2 10Gbps units Added clarification to APGV1 and APGV2 features Removed unused orange port LED state (Section 3.1.3.2) Added SYNC interface electrical specification (Section 3.2.3) Added Rear Panel Clock Interfaces, CLOCK-IN and CLOCK-OUT electrical specifications (Section 3.3) Added Inter-Unit Synchronisation Concepts: synchronous clock, timestamp and transmission (Section 5.6) Updated Edit-Settings pop-up window with Display and Sync Tabs (Section 6.3.5) Updated Control Panel with Reset Timestamp button (Section 6.6) Added Unit Sync option to Counter Panel (Section 6.7) Added Unit Control pop-up window (Section 6.9) |
| 14 December 2023 | 3.1 | <ul style="list-style-type: none"> Added Port BERT Option (Section 6.10.4) |
| 17 September 2024 | 3.2 | <ul style="list-style-type: none"> Removed CD from Box Contents (Section 2.1) Added 5Gbps/2.5Gbps Topology changes Corrected fan alert description (Section 6.9.1.4) |

Document Conventions



INFORMATION:
 Additional information to clarify functionality or usability



WARNING:
 Clarification of unexpected or restricted functionality



CRITICAL:
 Unit failure - contact Axtrinet for further support

Disclaimers

Axtrinet retains the right to make changes to this document at any time, without notice. The information in this document is believed to be accurate and reliable. Axtrinet does not warrant the accuracy or completeness of the information, text, graphics or other items contained within this document.

Axtrinet provides the software and the documentation "as is" without warranties of any kind.

Axtrinet disclaims all warranties and representations of any kind relating to products, software or services provided hereunder, whether express, implied, statutory, including without limitation the implied warranties of merchantability, fitness for a particular purpose, accuracy, or non-infringement of third party rights.

Axtrinet does not warrant that the software will in every case process all data correctly, or that operation of the products, including software, will be uninterrupted, free from error, or secure.

The disclaimers in this section will not apply to the extent prohibited by applicable law.

The software is not designed, intended, or certified for use in components of systems intended for the operation of weapons, weapons systems, nuclear installations, means of mass transportation, aviation, medical systems, devices, implants, or equipment, pollution control, hazardous substances management, or for any other dangerous application in which the failure of the products could create a situation where bodily injury or death may occur. The use of the software in any such application is solely at your own risk.

Copyright Statement

Copyright © 2016-2024 Xentech Solutions Limited, all rights reserved. The information contained in this document is the property of Xentech Solutions Limited. No part of this publication shall be reproduced, stored or transmitted in any form or by any means without the prior written permission of Xentech Solutions Limited.

Trademarks

Axtrinet is a trading name and registered trademark of Xentech Solutions Limited, registered in the UK.

Windows is a registered trademark or trademark of Microsoft Corporation, registered in the U.S. and other countries.

Wireshark is a registered trademark of the Wireshark Foundation.

Preface

About This Document

This document describes the Axtrinet Packet Generator hardware, the installation procedure, and the User Manual for the APG Control Interface. It contains the following sections:

| Section | Description |
|-------------------------------|---|
| 1. INTRODUCTION | Key features and benefits of the Axtrinet Ethernet Packet Generators |
| 2. INSTALLATION | Installation procedures for the Microsoft™ Windows™ and Linux USB drivers and Control Interface |
| 3. HARDWARE INTERFACES | Physical properties of the unit |
| 4. MANAGEMENT INTERFACES | Introduction to the Management Interfaces of the unit |
| 5. TEST ENVIRONMENT & CONCEPT | Introduction to Ethernet packet generation, packet structures and control |
| 6. CONTROL INTERFACE | Detailed guide to the APG Control Interface |

Related Documentation

- [1] APG-GSG Axtrinet APG Getting Started Guide
- [2] APG-TCL-UG Axtrinet APG TCL API Guide
- [3] APG-HDR Axtrinet APG Header Definitions
- [4] APG-SW-TC Axtrinet APG Software License Terms and Conditions

Visit www.axtrinet.com/axtrinet-support for the latest documentation.

Glossary

| | |
|-------|--|
| APG | Axtrinet Packet Generator |
| API | Application Programming Interface |
| BER | Bit Error Rate |
| BERT | Bit Error Rate Test |
| FCS | Frame Checksum |
| FPGA | Field Programmable Gate Array |
| Gb | Gigabits |
| Gbps | Gigabits per Second |
| IBG | Inter-Burst Gap |
| IFG | Inter-Frame Gap |
| LAN | Local Area Network |
| MB | Megabytes |
| Mbps | Megabits per Second |
| PLL | Phase Locked Loop |
| pps | Packets per Second |
| PPS | Pulse per Second (clock) |
| PRBS | Pseudo-Random Bit Sequence |
| QSFP+ | Quad Small Form-Factor Pluggable (40Gbps) |
| SFD | Start-of-Frame Delimiter |
| SFP | Small Form-Factor Pluggable (1Gbps) |
| SFP+ | Small Form-Factor Pluggable (10Gbps, 5Gbps, 2.5Gbps) |
| TCL | Tool Command Language |
| USB | Universal Serial Bus |

Contents

| | |
|--|-----------|
| 1. INTRODUCTION | 8 |
| 1.1 Main Features | 8 |
| 1.2 Benefits..... | 8 |
| 1.3 Safety Information..... | 9 |
| 1.4 Care of the Product..... | 9 |
| 1.5 Environmental..... | 10 |
| 1.6 Conformance | 10 |
| 1.7 Limited Hardware Warranty | 11 |
| 1.8 Software Licences and Support..... | 12 |
| 1.9 Contact Details..... | 12 |
| 2. INSTALLATION | 13 |
| 2.1 Box Contents | 13 |
| 2.2 Minimum System Requirements | 13 |
| 2.3 Linux Installation..... | 14 |
| 2.4 Windows Installation..... | 15 |
| 2.5 Connecting the Hardware | 16 |
| 2.6 Testing the Installation..... | 17 |
| 2.7 Setting the IP Address..... | 18 |
| 3. HARDWARE INTERFACES..... | 19 |
| 3.1 Front Panel Interfaces | 19 |
| 3.2 Rear Panel Interfaces | 22 |
| 3.3 Rear Panel Clock Interfaces (APGV2 units only) | 24 |
| 3.4 Physical Specifications..... | 25 |
| 4. MANAGEMENT INTERFACES | 26 |
| 4.1 APG Control Interface..... | 26 |
| 4.2 TCL Scripting | 26 |
| 5. TEST ENVIRONMENT & CONCEPTS..... | 27 |
| 5.1 Definitions | 27 |
| 5.2 Unit Configuration..... | 28 |
| 5.3 Port Topology..... | 28 |
| 5.4 Transmit Path | 29 |
| 5.5 Port Control | 32 |
| 5.6 Inter-Unit Synchronisation (APGV2 units only) | 32 |
| 5.7 Receive Path | 35 |
| 6. CONTROL INTERFACE | 36 |
| 6.1 Running the Control Interface | 36 |
| 6.2 Overview | 36 |
| 6.3 Menu Bar..... | 37 |
| 6.4 Connection Panel..... | 45 |
| 6.5 Stream Configuration Panel | 48 |
| 6.6 Control Panel | 51 |
| 6.7 Counter Panel | 52 |
| 6.8 Port Options Menu | 53 |
| 6.9 Unit Control Window (APGV2 units only)..... | 53 |
| 6.10 Port Status Window | 57 |
| 6.11 Capture Data Display | 61 |
| 6.12 Sliders | 61 |

1. INTRODUCTION

Thank you for purchasing an Axtrinet™ APG Ethernet Packet Generator.

The Axtrinet APG Ethernet Packet Generators provide compact and affordable 40Gbps and 10Gbps/5Gbps/2.5Gbps/1Gbps Ethernet Packet Generator/Analysers with a simple-to-use Control Interface and an open TCL API for third party scripting.

Ideally suited to applications in R&D, Test and Manufacturing environments, and 'on the road' with Field Sales and Application Engineers, the Axtrinet APG Ethernet Packet Generators allow reliable and affordable development and testing of:

- Ethernet network equipment such as switches, routers, firewalls and network monitoring devices with 10Gbps/5Gbps/2.5Gbps/1Gbps Ethernet Interfaces
- Data storage equipment with 1Gbps/10Gbps and 40Gbps (APGV1 only) Ethernet interfaces
- Specialist devices such as FPGA accelerator NIC cards and offload appliances
- Ethernet infrastructure installations encompassing cabling and switches

1.1 MAIN FEATURES

- Highly configurable Ethernet Packet Generation
- Full wire-speed operation on all ports
- Industry standard QSFP+ and SFP+/SFP ports
- Real-time packet counts and error detection
- Packet Capture for post-test analysis
- Simple to use Control Interface for configuration and control
- Clear LED status indication for unit operation and Ethernet traffic generation/reception
- USB 2.0 port for easy set up and local management and 10/100Mbps Ethernet LAN connection for flexible remote management

1.2 BENEFITS

- Low cost allows multiple units to be deployed in a development environment – one per desk
- Easy to set up and use. Avoids the need for complex vendor specific programming skills
- Ideal for integration into a manufacturing test environment using TCL scripting interface
- Flexible choice of interfaces allows use with different speeds and media types, maximising the investment across multiple projects
- Small size, 1U high (44mm) and 146mm wide, for desk-top or rack shelf mounting (1/3 rack width)

1.3 SAFETY INFORMATION



To prevent possible electrical shock, fire, personal injury, or damage to the product, carefully read this safety information before attempting to install or use the product.

In addition, follow all generally accepted safety practices and procedures for working with and near electricity.

The product has been designed in accordance with the European standard publication EN 61010-1:2010, and left the factory in a safe condition.

1.3.1 External Connections



To prevent injury or death, only use the power adapter and cord supplied with the product.



To prevent injury, ensure that light or laser light sources (eg from SFPs and QSFPs) are extinguished during connection or disconnection to optical fibre inputs. Never direct an optical source towards a naked eye.

1.3.2 Environment



To prevent injury or death, do not use in wet or damp conditions, or near explosive gas or vapour.



To prevent damage to the Packet Generator, use and store in the recommended environment:

| | Temperature | Humidity | Altitude |
|-------------------|---------------|----------------------------------|----------|
| Operating: | 0°C - +40°C | 5% to 90% RH (non-condensing) | 2000m |
| Storage: | -20°C - +55°C | | |

1.4 CARE OF THE PRODUCT

The Axtrinet Packet Generator contains no user-serviceable parts. Repair and servicing require specialised test equipment and must only be performed by Axtrinet. There may be a charge for these services unless covered by the Axtrinet one year warranty.



Use a soft damp cloth to clean the Axtrinet Packet Generator.



Do not allow liquids to enter the product casing, as this may cause damage to the electronics inside.



Do not tamper with or dismantle the Packet Generator. Internal damage may affect performance and void the warranty.



Do not block the air vents at the front of the Packet Generator or the fan exhaust at the rear. Overheating may affect the performance and damage the internal electronics.



Do not insert any objects through the air vents. Internal interference may damage the internal electronics.

1.5 ENVIRONMENTAL



Disposal of Waste Electrical & Electronic Equipment

When an Axtrinet Packet Generator reaches the end of its useful life, Axtrinet will arrange the responsible recycling of returned products. Where the customer wishes to return the unit to Axtrinet, the customer will be responsible for shipping the unit back to our facility. Before returning the unit, contact Axtrinet Customer Services at support@axtrinet.com for more information.

1.6 CONFORMANCE

1.6.1 UKCA Notice



The product meets the intent of the Electromagnetic Compatibility Regulations 2016 and is designed and certified to BS EN IEC 61326-1:2021 Class A Emissions and Basic Immunity standard.

This product is in conformity with the protection requirements of Electromagnetic Compatibility Regulations 2016 relating to electromagnetic compatibility. Axtrinet cannot accept responsibility for any failure to satisfy the protection requirements resulting from a non-recommended modification of the product.

The limits for Class A equipment were derived for commercial and industrial environments to provide reasonable protection against interference with licensed communication equipment.

Warning: This is a Class A product. In a domestic environment, this product may cause radio interference, in which case the user may be required to take adequate measures.

The product meets the intent of the Electrical Equipment (Safety) Regulations 2016 and has been designed to meet BS EN 61010-1:2010+A1:2019 Safety requirements for electrical equipment for measurement, control, and laboratory use.

1.6.2 CE Notice



The product meets the intent of the EMC directive 2014/30/EU and is designed and certified to EN61326-1:2013 Class A Emissions and Basic Immunity standard.

This product is in conformity with the protection requirements of EU Council Directive 2014/30/EU on the approximation of the laws of the Member States relating to electromagnetic compatibility. Axtrinet cannot accept responsibility for any failure to satisfy the protection requirements resulting from a non-recommended modification of the product.

The limits for Class A equipment were derived for commercial and industrial environments to provide reasonable protection against interference with licensed communication equipment.

Warning: This is a Class A product. In a domestic environment, this product may cause radio interference, in which case the user may be required to take adequate measures.

The product meets the intent of the Low Voltage Directive 2014/35/EU and has been designed to meet EN 61010-1:2010 Safety requirements for electrical equipment for measurement, control, and laboratory use.

1.6.3 FCC Notice



This equipment is intended for use solely as industrial test equipment, and is therefore exempt under Section 15.103(c) exemption rules.

However, this equipment has been verified to comply with the limits for a Class A digital device, pursuant to Part 15 (CFR 47) of the FCC Rules. These limits are designed to provide reasonable protection against harmful interference when the equipment is operated in a commercial environment. This equipment generates, uses, and can radiate radio frequency energy and, if not installed and used in accordance with the instruction manual, may cause harmful interference to radio communications. Operation of this equipment in a residential area is likely to cause harmful interference in which case the user will be required to correct the interference at their own expense.

1.7 LIMITED HARDWARE WARRANTY

Axtrinet warrants upon delivery, and for a period of one year unless otherwise stated from the date of delivery, that the product will be free from defects in material and workmanship.

Axtrinet shall not be liable for a breach of the warranty if the defect has been caused by wilful damage, negligence, abnormal working conditions or failure to follow Axtrinet's written advice on the storage, installation, commissioning, use or maintenance of the product; or if the Customer alters or repairs the product without the written consent of Axtrinet.

The maximum liability of Axtrinet under this warranty is limited to the purchase price of the product covered by the warranty.

EXCEPT AS SPECIFICALLY PROVIDED ABOVE OR AS REQUIRED BY LAW, THE WARRANTIES AND REMEDIES STATED ABOVE ARE EXCLUSIVE AND IN LIEU OF ALL OTHERS, ORAL OR WRITTEN, EXPRESS OR IMPLIED. ANY OR ALL OTHER WARRANTIES, INCLUDING IMPLIED WARRANTIES OF MERCHANTABILITY, FITNESS FOR A PARTICULAR PURPOSE AND NON-INFRINGEMENT OF THIRD PARTY RIGHTS ARE EXPRESSLY EXCLUDED. AXTRINET SHALL NOT UNDER ANY CIRCUMSTANCES BE LIABLE TO ANY PERSON FOR ANY SPECIAL, INCIDENTAL, INDIRECT OR CONSEQUENTIAL DAMAGES, INCLUDING WITHOUT LIMITATION, DAMAGES RESULTING FROM USE OR MALFUNCTION OF THE PRODUCT, LOSS OF PROFITS OR REVENUES OR COSTS OF REPLACEMENT GOODS, EVEN IF AXTRINET IS INFORMED IN ADVANCE OF THE POSSIBILITY OF SUCH DAMAGES.

Should a product fail to perform as described above within the warranted period, it will be repaired or replaced with the same or functionally equivalent product by Axtrinet, at its discretion, free of charge provided you: (1) return the product to a Axtrinet designated repair facility with shipping charge prepaid or by using the Returns Label provided, and (2) provide Axtrinet with proof of the original date of purchase.

Prior to returning any defective product, the end customer or the reseller from whom the end customer originally purchased the product must obtain a Return Materials Authorisation (RMA) number from Axtrinet. Unless otherwise agreed, all defective products should be returned to Axtrinet with shipping charges prepaid. Axtrinet will not accept collect shipments.

Repaired or replacement products will be returned to you with shipping charges prepaid.

Replacement products may be refurbished or contain refurbished materials. If Axtrinet, by its sole determination, is unable to repair or replace the defective product, it will refund the depreciated purchase price of the product.

An Extended Hardware Warranty is available for purchase; please contact Axtrinet or your reseller for more information.

1.8 SOFTWARE LICENCES AND SUPPORT

See the Axtrinet APG Software License Terms & Conditions [4].

Email based software support is included in the purchase price for the first 12 months after delivery. Extended Software Support is available for purchase; please contact Axtrinet or your reseller for more information.

1.9 CONTACT DETAILS

Technical assistance is available from Axtrinet at the following address:

Address: Xentech Solutions
 Suite 6 Stanta Business Centre
 3 Soothouse Spring
 St Albans
 AL3 6PF
 UK

Phone: +44 (0)1727 867795

Email:
 Technical Support: support@axtrinet.com
 Sales: sales@axtrinet.com

Web Site: www.axtrinet.com

2. INSTALLATION

This section describes the driver, APG Control Interface and TCL API installation process on a host PC running Linux or Windows.

2.1 BOX CONTENTS

The shipping carton contains:

- APG Unit
- Universal Desktop 12Vdc 5A Power Supply & local mains lead
- 1m USB Type B lead
- Getting Started Guide
- 4x Rubber Feet

Visit www.axtrinet.com/axtrinet-support for the latest documentation and software.

2.2 MINIMUM SYSTEM REQUIREMENTS

| | |
|-------------------|--|
| Processor | Pentium-class processor or equivalent |
| Memory | 2GB (4GB recommended) |
| Disk Space | 15MB |
| OS | 64bit (x86_64) Linux systems Microsoft Windows 7 Microsoft Windows 8.x Microsoft Windows 10.x Microsoft Windows 11.x |
| Interfaces | Minimum: USB 2.0 Preferred: USB 2.0 & 10/100Base-T |

2.3 LINUX INSTALLATION

The Axtrinet APG Linux package contains the GUI application and the system configuration file. The GUI requires X-Windows to be running.

There are 4 installation formats provided for convenience:

- Simple tar
- Pacman
- RPM
- Deb

Pick the one that suits the distribution and the package should install with the normal package handling tools or use the commands below.

Currently all packages are for 64bit (x86_64) linux systems. The package files may not have all package dependencies because package names vary between different linux distributions.

See the notes in the Dependencies section below for package dependencies.

Pacman

Install with

```
pacman -U apgcontrol-3.4-1-x86_64.pkg.tar.xz
```

Remove with

```
pacman -R apgcontrol
```

RPM

Install with

```
rpm -U apgcontrol-3.4-1.x86_64.rpm
```

or

```
yum localinstall apgcontrol-3.4-1.x86_64.rpm
```

Remove with

```
rpm -e apgcontrol
```

There are a set of MD5/SHA1/SHA256 sums for the package files.

The package includes a desktop link that should appear under Network tools.

If it doesn't work

Provided the package install worked, once installed there should be an executable 'apgcontrol' in /usr/bin. If it does not run then check for missing libraries with:

```
ldd /usr/bin/apgcontrol
```

Dependencies

The following base packages are required but will normally already be installed:

fontconfig, libxft, libx11

The following optional dependencies are also required for some functionality:

- To connect to USB ports **libusb** (libusb-1.0.so) is required. If it is not present, USB connected units will not appear.
- In addition to run the scripting interface you will require to have a **tcl** package (provide tclsh, libtcl8.6.so) installed and to run the test suite **tk** (provide wish) to run the UI and **texlive** or **texlive-bin** (provide pdflatex) to create the pdf report documents.


2.4 WINDOWS INSTALLATION

1. Insert the CD.
2. Locate "apg-install.exe" in the Windows directory
3. Run the installation file and follow the on-screen instructions to install the USB driver, APG Control Interface GUI and the APG TCL API.




DO NOT CONNECT THE AXTRINET PACKET GENERATOR TO THE WINDOWS PC UNTIL THE INSTALLATION IS COMPLETE.

4. Read and accept the software Licence Agreement:




5. Select the components to install:



The installer will only update the installed components if a newer component is available.

Click to start installing the selected components.

6. The window changes to display the installation progress.



7. completes the installation process.
8. In addition, to run the scripting interface you will require to have a **tcl** package (provide tclsh) installed; to run the Test Suite GUI you will require **tk** (provide wish); and to generate test reports you will require **TexLive** or **MiKTeX** (provide pdflatex).

2.5 CONNECTING THE HARDWARE

- Attach the ac mains supply lead to the power adapter, connect the adapter to the unit and apply power.
 - The POWER LED will be illuminated ORANGE for ~60 seconds while the hardware configures.




AN APGV1 unit will complete hardware configuration in ~60 seconds.
AN APGV2 unit will complete hardware configuration in ~25 seconds.

- The POWER LED will turn GREEN after successful configuration, or RED if the hardware has failed to configure.




If the POWER LED turns RED after configuration, contact AXTRINET for further support.

- Connect the management PC to the APG unit using the USB Type B lead (provided).



2.6 TESTING THE INSTALLATION

- Start the APG Control Interface:
 - On Linux, click the **home / Axtrinet Control** icon or execute **user/bin/apg_control**
 - On the Windows Start menu, locate the Axtrinet directory and click on the **APG Control** icon.
- The APG Control Interface management window will be displayed and the new unit will appear as a USB connection:




If the unit does not appear in the Control Interface, check that the unit is turned on and the USB lead is connected.




If installing the drivers onto a PC for the first time, it may be necessary to re-run the installation process after the device has been connected as the USB drivers may not be enabled.

- To connect to the unit, click on the Checkbox next to the device.



The unit port counters and unit Status button are displayed:



- The drivers and APG Control Interface have been successfully installed.

2.7 SETTING THE IP ADDRESS

The default settings are:

IP Address **192.168.1.100**

Mask **255.255.255.0**


Gateway **0.0.0.0**



You may need to contact your Network Administrator to obtain the required IP and Gateway Addresses

To change the IP Address of the unit:

- On the MENU BAR: Edit → Network Configuration.
The IP Configuration Window opens:



- Set the IP Address, Mask and Gateway Address, then click APPLY

For further details, see Section 6.3.6.

3. HARDWARE INTERFACES


The packet generator ports (SFP+/SFP & QSFP+) are on the front of the unit, and the management and power interfaces are on the rear.

3.1 FRONT PANEL INTERFACES


**APG4
APG4V2-10**



**APG8
APG8V2-10**



APG208



Status LEDs 10Gbps/1Gbps SFP+/SFP 10Gbps/1Gbps SFP+/SFP 40Gbps QSFP+

| | Up to 10Gbps/1Gbps SFP+/SFP | 40Gbps QSFP+ |
|---------------------------|-----------------------------|--------------|
| APG4 APG4V2-10 | 4 | 0 |
| APG8 APG8V2-10 | 8 | 0 |
| APG208 | 8 | 2 |

3.1.1 SFP+/SFP Interfaces

The SFP+/SFP interfaces will support 10Gbps/5Gbps/2.5Gbps SFPs that meet SFF-8431 MSA and 1Gbps SFPs that meet INF-8074 MSA.

The list of verified SFPs is available on the Axtrinet website:

<https://www.axtrinet.com/axtrinet-support>

The SFP+/SFP interfaces will also support certain 10GBase-T transceivers that exceed the SFF-8431 power budget of 1W, but only in the upper ports (1,3,5,7) due to thermal limitations.



Up to 8x **Axtrinet AXB891-2-5-10GBT** transceivers can be supported in an APGV2 unit when operating in 1000Base-T or 2500Base-T mode over the full operating temperature range.

When operating in 8x 5000Base-T or 10GBase-T modes, it is recommended to operate in an ambient temperature < 25°C otherwise the unit may overheat and shut down.



If **not** using the Axtrinet 10GBase-T SFPs, it is recommended that 10GBase-T transceivers are only used in the upper ports (1,3,5,7). 10GBase-T transceivers in the lower ports (2,4,6,8) may overheat.



1000Base-T transceivers can be used in any SFP port

3.1.2 QSFP+ Interfaces (APG208 only)


The QSFP+ interfaces will support 40Gbps QSFPs that meet SFF-8436 MSA.

The list of verified QSFPs is available on the Axtrinet website:

<https://www.axtrinet.com/axtrinet-support>




The QSFP+ interfaces can be configured in 40Gbps mode (default) or 4X10Gbps mode, where each of the 10Gbps lanes that comprise the 40Gbps link are managed independently (Section 5.3). Switching between 40Gbps and 4x10Gbps modes is performed in the Port Control Window (Section 6.10.1).

3.1.3 LED Indicators



Some APG units are fitted with SFP Cages with four LEDs per vertical port pair. In all cases, only the outer LEDs are used. The inner two LEDs are not used.

3.1.3.1 System LEDs

| LED | Colour | Description |
|----------------|--------|--|
| ERR | RED | Operational Unit Error eg over-temperature |
| | OFF | Unit OK |
| | OFF | Normally OFF |
| MGMT | GREEN | Configuration or Status information is being read from the unit |
| | AMBER | Configuration or Status information is being written to the unit |
| | OFF | Unit is not being actively managed |
| PWR | GREEN | Unit is powered and OK |
| | AMBER | Unit is powered and configuring the hardware |
| | | <div style="border: 1px solid #ccc; background-color: #e6f2ff; padding: 10px; margin: 10px 0;">  <p>After applying the power on an APGV1 unit, the POWER LED will be illuminated ORANGE for ~60 seconds while the hardware configures. After applying the power on an APGV2 unit, the POWER LED will be illuminated ORANGE for ~25 seconds while the hardware configures.</p> </div> |
| Flashing AMBER | | Processing downloaded file (3-4 minutes) |
| RED/AMBER | | Failed to configure the hardware |
| | | <div style="border: 1px solid #ccc; background-color: #ffe6e6; padding: 10px; margin: 10px 0;">  <p>Power cycle the unit. If the problem persists, contact AXTRINET for Technical Support.</p> </div> |
| RED | | Initial state immediately after the power has been applied. If the LED remains on for >5 sec, critical hardware fault detected |
| | | <div style="border: 1px solid #ccc; background-color: #ffe6e6; padding: 10px; margin: 10px 0;">  <p>Power cycle the unit. If the problem persists, contact AXTRINET for Technical Support.</p> </div> |
| OFF | | Unit is not powered |


3.1.3.2 Port LEDs

One LED per port, integrated into the transceiver cage:

| Colour | Meaning |
|--------|---|
| GREEN | Steady Link OK, no traffic Flashing Transmit or Receive Traffic Activity |
| RED | Steady Transmit disabled → set TXENABLE on Port Control tab (Section 6.10.1) |
| OFF | No Link |

3.2 REAR PANEL INTERFACES

USB and 10/100Base-T Ethernet interfaces provide management access to the device.



3.2.1 USB Interface

The USB 2.0 Type B interface can be used to provide a connection to the PC running the Control Interface Application Software.



a) Direct Connection


b) Multiple APG units connected through USB Hub

After installing the Control Interface Application Software, no further configuration is required to enable the USB interface.


3.2.2 10/100Base-T Ethernet Interface

The 10/100Base-T RJ45 interface can be used to provide a network connection to the PC running the Control Interface Application Software or TCL API Scripting.

The Ethernet connection can be direct, or across a LAN, or WAN to a remote office.



c) Multiple APG units connected through LAN



d) Multiple APG units connected through WAN

After installing the Control Interface Application Software, the Network Interface must be configured using the USB Interface to set the IPV4 Address, Mask and Gateway (Section 6.3.6).



Up to two Ethernet connections are supported by the Ethernet Interface, eg two Control Interface sessions or one Control Interface session and one TCL session.

3.2.3 SYNC Interface

The SYNC Interface allows multiple Axtrinet units to be connected together to enable synchronisation functions:

- Synchronous start of packet generation
- Synchronous timestamp reset (APGV2 only)

The SYNC Interface provides an ANSI/TIA/EIA-485 interface from a standard female SMA connector on the rear panel for connection to a standard male SMA connector on a cable or T-piece. Coaxial cable is recommended.

The SYNC interface is bi-directional, acting as an output in SYNC master mode, and an input in slave mode.

The maximum cable length between connected units is recommended to be less than 1m.



With short co-axial cables, a single 120Ω SMA termination is recommended at one end of the connecting cable(s).




| | Min | Typ | Max |
|--------------------|-------|-----|------|
| Input High | 2.0V | | 7.0V |
| Input Low | -3.0V | | 1.3V |
| Input Pulse Width | 5ns | | |
| Input Impedance | 12KΩ | | |
| Input Current | | | 2mA |
| | Min | Typ | Max |
| Output High | 2.0V | | 3.3V |
| Output Low | 0V | | 0.8V |
| Output Pulse Width | | 5ns | |

3.2.4 Power


The APG unit requires a 12V 5A from the ac/dc power supply provided.

The DC Jack is 2.1mm internal diameter, 5.5mm external diameter, 9.5mm minimum length, with the centre pin positive.



| | Min | Typ | Max |
|---------------|------|-------|-------|
| Input Voltage | 9.0V | 12.0V | 14.0V |

3.3 REAR PANEL CLOCK INTERFACES (APGV2 UNITS ONLY)



The CLOCK-IN and CLOCK-OUT Interfaces provide ANSI/TIA/EIA-485 interfaces from standard female SMA connectors on the rear panel for connection to a standard male SMA connector on a cable or T-piece. Coaxial cable is recommended.


The maximum cable length between connected units is recommended to be less than 1m.



With short co-axial cables, a single 120Ω SMA termination is recommended at one **end** of the connecting cable(s).

3.3.1 CLOCK-IN

The clock input is used to synchronise the internal system clock to an external reference (1PPS or 1MHz)



| | Min | Typ | Max |
|-----------------|-------|-----|------|
| Input High | 2.0V | | 7.0V |
| Input Low | -3.0V | | 1.3V |
| Input Current | | | 2mA |
| Input Impedance | 12KΩ | | |

| | 1PPS (1Hz) Mode | 1MHz Mode |
|---------------|-----------------|-----------|
| Frequency | 1Hz | 1MHz |
| PLL Lock Time | 120 sec | 2 sec |
| Tolerance | ±100ppm | ±100ppm |

The internal system clock state is displayed in the Unit Configuration window in the APG Control Interface (Section 6.9).

3.3.2 CLOCK-OUT

All Axtrinet units output a 1PPS or 1MHz reference clock on the CLOCK-OUT, depending on the clock source setting.




| | Min | Typ | Max |
|-------------|------|-----|------|
| Output Low | 0V | | 0.8V |
| Output High | 2.0V | | 3.6V |

3.4 PHYSICAL SPECIFICATIONS


- Width: 140mm (5.51")
- Depth: 228mm (8.97")
- Height: 44mm (1.73")
- Weight: 1.20 kg (2.65 lb)

4. MANAGEMENT INTERFACES



APG Control Interface
APG TCL Scripting

4.1 APG CONTROL INTERFACE



The Axtrinet APG Control Interface is a custom application providing:

- unit, port and stream configuration and status
- port control (start, step, stop)
- packet counters (packets, bytes, errors)
- receive packet capture tools

The Axtrinet APG Control Interface is described in Section 6.

4.2 TCL SCRIPTING

The Axtrinet APG API provides a TCL scripting interface for automated test generation.


The API provides access to:

- unit, port and stream configuration and status
- port control (start, step, stop)
- packet counters (packets, bytes, errors)
- receive packet capture tools

The Axtrinet APG API Interface is described in the TCL API Guide [2].

5. TEST ENVIRONMENT & CONCEPTS

The Test Environment consists of one or more Axtrinet Packet Generators. A single unit may be connected over a direct USB connection, or multiple units may be connected over USB or Ethernet. The units may be located in the same location, or in geographically separate locations connected by a WAN.



All accessible units can be managed through the same Control Interface or TCL scripting interface.

5.1 DEFINITIONS

| | |
|----------------|---|
| UNIT | <p>A unit is a single physical Axtrinet Packet Generator (eg APG208).</p> <p>A unit is assigned a UNITID when the management connection is first opened using the Control Interface (or TCL API). The UNITID is fixed for the duration of the Control Interface session, and is used to uniquely identify a unit during the session. The UNITIDs will be reassigned if the application is restarted.</p> <p>The UNITID can be seen in the Connection Panel (Section 6.4) and in the port label in the Counters Panel (Section 6.6).</p> |
| PORT | <p>A PORT is a physical aperture on the unit (SFP+/SFP or QSFP+).</p> <p>The port-level functions configure the port settings and monitor the port status (Section 6.10.1) and view the captured packets (Section 6.10.2).</p> <p>Ports must be selected (Section 6.6) to start/step/stop transmission (Section 6.6).</p> |
| SUBPORT | <p>Where a QSFP+ port can be configured into different topologies (eg 40Gbps or 4x10Gbps), the PORTID is qualified with a SUBPORT.</p> <p>Subports are numbered from 1.</p> |
| MODULE | <p>A MODULE is a SFP+/SFP or QSFP+ transceiver, and must be inserted into a port aperture to enable a link.</p> <p>The module-level functions configure the module settings (Section 6.10.1), and monitor the module status (Section 6.10.2).</p> |
| STREAM | <p>A transmit stream generates a controlled number of Ethernet frames with a defined length and rate (Section 6.5.1); fixed header configuration with a fixed or varying header contents (Section 6.5.2); and a fixed or varying payload (Section 6.5.3).</p> <p>The outputs from the eight stream generators are multiplexed into a single stream for transmission from a port.</p> |

5.2 UNIT CONFIGURATION

The unit, port and stream configuration is stored on the unit.

The APG Control Interface provides a graphical interface to view and modify the configuration stored on the unit, to view the counters and the captured data. The current configuration can be saved locally to a named file and then loaded onto a unit later.

Unit, port and stream configurations can be modified within the Control Interface and APPLIED to the unit.

The unit will retain its configuration over a power cycle.

5.3 PORT TOPOLOGY

Port Topology defines the physical port configuration (eg 40Gbps, 4x10Gbps), rather than the interface type (eg QSFP+).

5.3.1 SFP+/SFP Ports

The SFP+/SFP Port Topology can be 10Gbps, 5Gbps, 2.5Gbps or 1Gbps .




On APGV1 units only, the unit will reboot after switching 10Gbps/1Gbps Topology.


5.3.2 QSFP+ Ports (APG208 only)

The QSFP+ interface is a composite port made up of 4x 10Gbps. The topology can be configured in 40Gbps mode (default) or 4X10Gbps mode, where each of the 10Gbps lanes that comprise the 40Gbps link are managed independently.

Changing the port topology of a QSFP+ port changes both the transmit and receive paths.



a) QSFP+ Port in 40Gbps Topology (default)



b) QSFP+ Port in 4x10Gbps Topology

Switching between 40Gbps and 4x10Gbps topologies is performed in the Port Control Window (see Section 6.10.1).




Mixed topology of the QSFP+ ports is **only** available with Port 9 at 4x10Gbps, and Port 10 at 40Gbps. Setting Port 9 to 40Gbps or Port 10 to 4x10Gbps topologies will automatically switch the other port into the same mode.

5.4 TRANSMIT PATH

Each port contains a transmit engine that comprises:

- 8 parallel independent configurable Ethernet stream generators
- Stream multiplexer
- Transmit port configuration and status
- Module configuration and status



The streams are processed in a round-robin sequence, transmitting a packet if it queued and ready to send.




To bring a link up, both the port and module must be enabled.
To transmit a stream, the port, module and stream must be enabled.
The transmit mode must be CONTINUOUS or a non-zero BURST.



Transmit PRBS Mode is supported on APGV2 units only.

5.4.1 Stream Generation


The Stream Generator defines an Ethernet frame:



A transmit stream generates a controlled number of Ethernet frames at a controlled length and rate; with a fixed header configuration, fixed or varying header contents, and a fixed or varying payload.

Each stream can be enabled or disabled (Section 6.5.1).

The stream transmit mode defines how the packets are generated: either Continuously; as a Single Burst of BURST LENGTH packets; or a Multiple Burst of BURST LENGTH packets, repeated BURST COUNT times, separated by BURST GAP (Section 6.5.1).



The stream transmit rate defines how quickly the packets are generated; either a percentage of the maximum rate; packets per second; or a gap defined by transmit clock cycles (Section 6.5.1).




Care should be taken to ensure that the cumulative stream transmit rates does not exceed the port capacity.

If the cumulative stream transmit rates does exceed the port capacity, the port will transmit at wire rate, but the streams will transmit at a lower rate than configured.

The length defines the total length of the frame in bytes, including the headers, payload, timestamp (if enabled) and 4-byte Frame Checksum (FCS). The length can be fixed, or incrementing, decrementing or random over a range (Section 6.5.1).

The HEADER is created by adding header types (eg MAC, VLAN, IPV4) to the stream (Section 6.5.2).



The payload can be fixed, or incrementing, decrementing or random (Section 6.5.3)

The payload may optionally include a 'Timestamp' field, comprising an ID, sequence number and timestamp (Section 6.5.3).



The Timestamp ID field is fixed at 0x0 in APG Control Interface Version 3.4.



The Sequence Number is set to zero when the unit powers up, and increments continuously for each packet transmitted with the Timestamp field enabled.

The Sequence Number will wrap after 2^{32} (4,294,967,296) packets.

Wire-rate 64 byte packets at 40Gbps will take 1 min 12 secs.

The Sequence Number can be reset in APG Control Interface Version 3.2.



On a APGV1 unit, the Timestamp indicates the time in 8ns cycles since the unit was reset. It is not possible to reset the timestamp



On a APGV2 unit, the Timestamp indicates the time in 2.5ns cycles since the unit was reset. The Timestamp **can** be reset in APG Control Interface Version 3.2.

A port can be enabled or disabled (Section 6.6), or run in PRBS mode (Section 6.10.4).

Port link status, link speed and transmit counters (Section 6.6) are available.

A module can be enabled or disabled (Section 6.10.1).

The module type, vendor and capabilities are available (Section 6.10.2).

5.5 PORT CONTROL


On the APG Control Interface Counter Panel (Section 6.7), ports can be selected individually or grouped for control using the Control Panel (Section 6.6).

The START button starts packet generation of the enabled streams.

STOP stops the packet generation. START will restart the packet generation from the first packet.

PAUSE interrupts the packet generation. START continues the packet generation from where it was paused.

STEP generates only the next packet, then pauses.



5.6 INTER-UNIT SYNCHRONISATION (APGV2 UNITS ONLY)

The Axtrinet unit uses an internal oscillator to clock a PLL-based clock synthesiser to generate the system clocks for the Ethernet Packet Generator, Ethernet and USB management interfaces. The clocks on separate APG units are free-running and will not be frequency or phase locked to each other.

Each unit has a SYNC interface and CLOCK-IN / CLOCK-OUT interfaces. The SYNC interfaces on each unit must be connected together; and the CLOCK-OUT from the master unit must be connected to the CLOCK-IN interfaces on the slave units for inter-unit synchronisation.


5.6.1 Clock Synchronisation

The Clock Interfaces allow multiple units to be connected together to synchronise system clocks to an external 1PPS (1HZ) or 1MHz reference. The reference can be generated locally from one of the connected Axtrinet units; or from an external timing reference source.

The synchronisation signal is a 1PPS or 1MHz clock. The electrical specification is defined in Section 3.3.1.



a) Multiple APG units synchronised locally



b) Multiple APG units synchronised from external source

Clock source is a unit function, and is set in the Unit Configuration window in the APG Control Interface (Section 6.9.1). If using a locally generated clock source, **one** unit must be set to the INTERNAL clock source (ie Clock Master); and the other units must be set to EXTERNAL clock source (ie Clock Slaves). If using an external reference source, all units must be set to EXTERNAL clock source. The synchronisation frequency (1PPS or 1MHz) must match on all connected units.

The clock status is displayed on the Unit Clock Control Configuration window (Section 6.9.1)



Short co-axial cables (<50cm) are recommended to connect the CLOCK-OUT to the CLOCK-IN interfaces. Very short cables (<20cm) are preferable. For optimum performance, a single 120Ω termination load is recommended at a 'slave' end of a short (<50cm) clock connection. 120Ω terminations loads are recommended at **both** ends of a long clock connection.



System clocks on the slave units will be frequency and phase locked to the master clock. If the CLOCK-OUT is enabled on the slave units, the 1PPS or 1MHZ output on the synchronised units will not be phase aligned.


5.6.2 Timestamp Synchronisation

Timestamp synchronisation requires the rear panel SYNC interfaces are connected between the units (Section 3.2.3); and access to the APG Control Interface (Section 6.7)

The synchronisation pulse can be generated locally from one of the connected Axtrinet units; or from an external pulse generator. The electrical specification is defined in Section 3.2.3.



a) Multiple APG units synchronised locally



b) Multiple APG units synchronised from external source

By default, the APG Control Interface will manage the timestamp synchronisation automatically by allocating the master and slave units within the 'unit synchronisation group'. Alternatively, the group and master can be selected manually on the Unit Sync Control Configuration window (Section 6.9.2).

The timestamp reset mode can be set in the Edit Setting – Sync window (Section 6.3.5.2) to zero or current (Unix) time.




Very short co-axial cables (<20cm) are recommended to connect the SYNC interfaces. For optimum performance, a single 120Ω termination load is recommended at a 'slave' end of a short (<50cm) sync connection. 120Ω terminations loads are recommended at **both** ends of a long sync connection.

The 'synchronised' ports will reset the timestamp on the rising edge of the synchronisation pulse.

5.6.3 Transmit Synchronisation

Transmit synchronisation requires the rear panel SYNC interfaces are connected between the units (Section 3.2.3); and access to the APG Control Interface (Section 6.7)

The synchronisation pulse can be generated locally from one of the connected Axtrinet units; or from an external pulse generator. The electrical specification is defined in Section 3.2.3.



By default, the APG Control Interface will manage the transmit synchronisation automatically by allocating the master and slave units within the 'unit synchronisation group'. Alternatively, the group and master can be selected manually on the Unit Sync Control Configuration window (Section 6.9.2).



Very short co-axial cables (<20cm) are recommended to connect the SYNC interfaces. For optimum performance, a single 120Ω termination load is recommended at a 'slave' end of a short (<50cm) sync connection. 120Ω terminations loads are recommended at **both** ends of a long sync connection.

The 'synchronised' ports will start transmitting on the rising edge of the synchronisation pulse.




The transmit timestamp of the **first** transmitted packet will be within ±1 clock cycle across any port on any unit (APGV1 ±8ns, APGV2 ±2.5ns)

5.7 RECEIVE PATH

Each port contains a receive path that comprises:

- Receive port mode, status and counters
- Configurable Capture Buffer



Receive PRBS Mode is supported on APGV2 units only.



Configurable Capture Filters are not supported in APG Control Interface Version 3.4. All received port traffic is forwarded to the capture buffer.

A 64KB capture buffer is available per 10Gbps port, that can be enabled or disabled, cleared and displayed (Section 6.10.2).

A 256KB (4x64KB) capture buffer is available per 40Gbps port (APGV1 only), that can be enabled or disabled, cleared and displayed (Section 6.10.2).



The 10Gbps Capture Buffer will capture undersize packets in the range 17-63 bytes. The 40Gbps Capture Buffer does not capture undersize packets. (APGV1 only)

An extended deep capture buffer is available, shared between the ports.

On an APGV1 unit, an extended 1GB capture buffer is available, allocated as follows:



64MB is allocated to each 10Gbps port
256MB is allocated to each 40Gbps port

On an APGV2 unit, an extended 2GB capture buffer is available, allocated as follows:



128MB is allocated to each port

Access to the 'deep' capture memory can be enabled or disabled per port.

The port receive counters and captured packets (Section 6.10.2) are available.

6. CONTROL INTERFACE

The section describes the Control Interface for Windows and Linux.

6.1 RUNNING THE CONTROL INTERFACE

6.1.1 Linux

Click on the **home / Axtrinet Control** icon or execute **usr/bin/apg_control**


6.1.2 Windows

Click on the APG Control icon in the Start Menu \ Axtrinet directory.

6.2 OVERVIEW

The APG Control Interface comprises 5 areas:

| | |
|-----------------------------------|---|
| Menu Bar | APG Control Interface configuration and settings. See Section 6.3 |
| Connection Panel | Open/Close management connections to the packet generator units. See Section 6.4 |
| Stream Configuration Panel | Port Stream Configuration See Section 6.5 |
| Control Panel | Start/Stop packet generator and clear counters See Section 6.6 |
| Counter Panel | Packet Generator counters and port control. See Section 6.7 |



6.3 MENU BAR

| File | Edit | Tools | About |
|---------|-----------------------|--------------|-------|
| Save | Settings | Upgrade Unit | |
| Save As | Network Configuration | | |
| Load | Counter Configuration | | |
| Exit | | | |

6.3.1 File – Save

Saves the default Control Interface configuration:

- IP Addresses of known units
- Connection status
- Counter configuration and Panel settings
- Port visibility

The default configuration is used when the Control Interface starts.

6.3.2 File – Save As

Saves the current Control Interface configuration, including:

- APG Control Interface layout, settings and port counters
- Port and Stream configuration for all connected units

A “File Save As” window appears to select the save file name and location.


The saved configuration file has a .apg extension.

Saved configurations can be applied using the Load Configuration option.

6.3.3 File – Load

Loads a saved configuration file to selected unit(s).

The “Load Config from File” window appears to select the configuration file and select the data to be applied to the current configuration.



| Button | Action |
|--|--|
| <input type="button" value="Browse"/> | Opens the "File Load" window to select the load file name and location. Alternatively, the path and filename can be entered manually. The path and filename default to the last used settings. |
| <input type="checkbox"/> <input checked="" type="checkbox"/> | Disable\Enable Configuration change |
| <input type="button" value="Apply"/> | Applies the saved configuration to the selected options |
| <input type="button" value="Refresh"/> | Refreshes the list of connected units |
| <input type="button" value="Cancel"/> | Closes the Load Configuration window without applying the changes. |

Select the saved configuration file either by entering the path and filename (.apg extension) manually or by clicking the button to open the File Selection window to select the directory and filename.

Opening the selected file automatically parses the saved configuration where the contents are analysed to determine how many units were included in the saved configuration.

The saved 'GUI Layout' and 'Counter Selection' will be applied if the corresponding checkbox is enabled. The stream configuration is always applied.

A list of saved serial numbers and unit types are displayed, with a corresponding 'apply' list of currently connected units. The connected unit list can be updated using the button.

The checkbox must be enabled to load the saved configuration onto the target unit.

The 'apply' unit does not have to be the same serial number or type, and saved ports will be applied if the port exists on the target unit.

The configuration is applied to the APG Control Interface and connected units using the button.

6.3.4 File – Exit

Closes the connections to APG units and close the Control Interface.




The APGs will continue to run and generate packets when the Control Interface is not connected.

6.3.5 Edit – Settings

6.3.5.1 Display Tab


The APG Control Interface can be configured on the Display Settings tab:



| Option | Description |
|------------------|--|
| Align | Align counter values LEFT or RIGHT |
| Comma Separators | Add 'thousand' separators to the counter values |
| Polling | Automatically poll the connected units every 'interval' The polling interval is adjustable between 0.5 – 2 seconds. |

6.3.5.2 Sync Tab (APGV2 units only)

The Timestamp Reset Mode is an APG Control Interface setting, and can be configured on the Sync tab:




| Option | Description |
|-----------------------|--|
| Reset to zero | Resets the packet timestamp counter to zero |
| Reset to current time | Resets the packet timestamp counter to Unix time, measured in APG unit clock cycles (APGV1 = 8ns; APGV2 = 2.5ns) |



Timestamp Reset is not supported on APGV1 units.

6.3.6 Edit – Network Configuration

The network configuration is entered using the Network Configuration window:



You may need to contact your Network Administrator to obtain the required IP and Gateway Addresses

The serial number of the target unit is displayed. If more than one unit is connected through the APG Control Interface, select the desired unit from the drop-down list of available unit serial numbers.

The current IP settings of the selected unit are displayed.

The default settings are:

| | |
|-------------------|----------------------|
| IP Address | 192.168.1.100 |
| Mask | 255.255.255.0 |
| Gateway | 0.0.0.0 |

| Button | Action |
|--|---|
|  | Applies the Network Configuration changes to the unit. |
| <div data-bbox="395 1400 469 1473" data-label="Image"> </div> <div data-bbox="496 1395 1423 1529" data-label="Text"> <p>Changing the Network Configuration while connected to the unit over a network connection will immediately disconnect the unit from the APG Control Interface. Open a new connection with the new address to continue to manage the unit.</p> </div> | |
|  | Closes the Network Configuration window without applying the changes. |




6.3.7 Edit – Counter Configuration

Counters (eg TxPackets), status indicators (eg Speed) and calculated values (eg TxRate) can be added or removed from the Counter Panel display list, and re-ordered within the display list.

All counters are always active, so can be viewed or hidden without affecting the counter values.

Counter management is performed using the Counter Configuration window:



The following control buttons are available:

| Button | Action |
|--------|---|
| | Adds the selected counters to the DISPLAY COUNTER pane at the <i>insert point</i> . The <i>insert point</i> can be moved UP and DOWN using the EARLIER and LATER buttons. |
| | Adds a spacer to the DISPLAY COUNTER pane at the <i>insert point</i> |
| | Moves the currently selected counters in the DISPLAY COUNTER pane UP |
| | Moves the currently selected counters in the DISPLAY COUNTER pane DOWN |
| | Removes the selected counters from the DISPLAY COUNTER pane |
| | Applies the Counter Configuration changes to the Control Interface. The displayed counters will update immediately. |
| | Closes the Counter Configuration window. |

The following status indicators are available:

| Status | Description |
|--------|--|
| Speed | 1Gbps, 2.5Gbps, 5Gbps, 10Gbps or 40Gbps 10Mbps, 100Mbps with 1000Base-T SFP Transceiver |
| Link | UP or DOWN |
| TxTime | Time in seconds since the START button was pressed |

The following transmit counters are available:

| Transmit | Description |
|-----------------|---|
| TxBytes | Transmit Bytes |
| TxPackets | Transmit Packets |
| Tx64 | Transmitted Packets with length equal to 64 bytes |
| Tx65-128 | Transmitted Packets with length between 65 and 128 bytes |
| Tx129-256 | Transmitted Packets with length between 129 and 256 bytes |
| Tx257-512 | Transmitted Packets with length between 257 and 512 bytes |
| Tx513-1024 | Transmitted Packets with length between 513 and 1024 bytes |
| Tx1025-1536 | Transmitted Packets with length between 1025 and 1536 bytes |
| Tx1537-9000 | Transmitted Packets with length between 1537 and 9000 bytes |
| Tx>9000 | Transmitted Packets with length greater than 9000 bytes |

The following receive counters are available:

| Receive | Description |
|----------------|---|
| RxBytes | Receive Bytes |
| RxPackets | Valid Receive Packets |
| Rx64 | Valid Receive Packets with length equal to 64 bytes |
| Rx65-128 | Valid Receive Packets with length between 65 and 128 bytes |
| Rx129-256 | Valid Receive Packets with length between 129 and 256 bytes |
| Rx257-512 | Valid Receive Packets with length between 257 and 512 bytes |
| Rx513-1024 | Valid Receive Packets with length between 513 and 1024 bytes |
| Rx1025-1536 | Valid Receive Packets with length between 1025 and 1536 bytes |
| Rx1537-9000 | Valid Receive Packets with length between 1537 and 9000 bytes |
| Rx>9000 | Valid Receive Packets with length greater than 9000 bytes |



Capture Filters are not supported in APG Control Interface Version 3.4

The following error counters are available:


| Errors | Description |
|---------------|--|
| FCS | Frame Checksum Errors Received |
| Undersize | Short packets (<64 bytes) with a valid SFD and FCS |
| Fragments | Packets without a valid SFD |
| NoSFD | Received Packet without a valid SFD |

The following calculated values are available:

| Calculated | Description |
|-------------|--|
| TxRate | Transmit Bit Rate in gigabits per second |
| Tx PPS | Transmit Packets per Second |
| RxRate | Receive Bit Rate in gigabits per second |
| Rx PPS | Receive Packets per Second |
| %FCS/RxPkts | FCS Error Rate (percentage) |

6.3.8 Tools – Upgrade Unit

The embedded software and FPGA firmware can be updated through the download window:



Select the target unit by the serial number from the dropdown list.

The current embedded software and FPGA firmware versions loaded on the unit are displayed.

Select the directory and download image from the file browser. The download image contains both the embedded software and FPGA firmware images.

| Option | Action |
|--------|---|
| | Applies the download file to the unit. |
| | Closes the window without downloading new software. |


To continue the firmware download, click 'yes' when the confirmation window appears:



If an invalid file is selected, the following message is displayed:




The progress window appears while the image is downloaded to the unit:



i An image download on an APGV1 unit takes 2-3 minutes
An image download on an APGV2 unit takes ~40 seconds

When the download completes, the "download complete" message is displayed and the unit reboots:




The PWR LED flashes amber while the new image is processed and saved into FLASH memory.

i Re-FLASH on an APGV1 unit takes 3-4 minutes
Re-FLASH on an APGV2 unit takes ~1 minute.

The unit then boots normally.

6.3.9 About

Displays the current APG Control Interface version:



6.4 CONNECTION PANEL

Connection to APG units using USB or Ethernet management interfaces is achieved through the Connection Panel. Units using the USB interface will always be visible in the Connection Panel.

Connections to networked units must be defined using the button. Click on the Connect Checkbox to toggle the management connection.



The USB interface does not display a connection status. The Unit Status, serial number and ID are greyed out when not connected.




The visible ports are automatically added to the counter pane when the management interface is connected.




If an attempt is made to connect using the USB and the Ethernet interfaces on the same unit from the same APG Control interface, the second attempted connection will fail.

The Ethernet management status is displayed next to the IP address:

| Status | Description |
|---|---|
| <input type="text"/> | Connection not attempted during this APG Control Interface session |
| <input type="text" value="connecting.."/> | Connect Checkbox ticked, connecting to the APG |
| <input type="text" value="connected"/> | Connection successful and management interface active. |
| <input type="text" value="disconnecting.."/> | Connect Checkbox cleared, disconnecting from the APG |
| <input type="text" value="closed"/> | Management connection closed |
| <input type="text" value="Unit API not supported"/> | If the Unit API is incompatible with the GUI API, the management connection is refused. |


 Download the latest Embedded Software from <https://www.axtrinet.com/axtrinet-support> Then use the "Upgrade Unit" tool (Section 6.3.8)

| | |
|---|---|
| <input type="text" value="connect failed"/> | Failed to connect to the APG management interface |
|---|---|

 **If the connection fails, check:**


- IP Address
- Can you ping the APG unit?
- Is the APG unit connected to the network?
- Is the IP address configured on the APG unit?
- If trying to connect from a different subnet or network, is the gateway address configured on the APG unit?

The PORT EXPANDER opens the PORT VISIBILITY list.



Checkboxes next to each port change the port visibility in the Counter Pane.

6.4.1 Status Window



The System Status summary displays the following information:


| Option | Function |
|----------------------|---|
| Serial Number | Serial number of the unit |
| Unit Status | <p>TEMP:</p> <ul style="list-style-type: none"> ● Temperature OK ● Temperature Warning – fan speed will increase ● Over-Temperature – front panel disabled <hr/> <p>FAN:</p> <ul style="list-style-type: none"> ● Fan OK ● Fan is running faster than expected ● Fan has failed or is running at full speed <hr/> <p>SELF-TEST:</p> <ul style="list-style-type: none"> ● Self-Test passed ● Self-Test running ● Self-Test Failed (READY status will also be RED) <hr/> <p>READY:</p> <ul style="list-style-type: none"> ● Unit OK and ready to generate Ethernet Traffic ● Unit booting ● Unit failed |
| Up Time | Time since the unit was turned on |
| Versions | Hardware, Embedded Software and Processing Core (FPGA) versions and date codes. |

6.5 STREAM CONFIGURATION PANEL

Stream Configuration is defined in the Stream Configuration Panel.

Each port contains 8 parallel independent configurable Ethernet stream generators.





Each stream generates a controlled number of Ethernet frames at a controlled length and rate; with a fixed header configuration, fixed or varying header contents, and a fixed or varying payload.



6.5.1 Transmit Control


The stream transmit mode, rate and length are configured in the Transmit Control Panel.

| Option | Setting | |
|---------------------|-----------------|---|
| ENABLE | ON | Enable stream for port transmission. |
| | OFF | Disable stream |
| MODE | CONTINUOUS | Transmit continuously until STOPPED or PAUSED |
| | SINGLE BURST | Transmit BURST LENGTH packets, or until STOPPED or PAUSED |
| | MULTIPLE BURSTS | Transmit BURST LENGTH packets, wait BURST GAP cycles, and repeat BURST COUNT times, or until STOPPED or PAUSED |
| BURST LENGTH | | Number of packets transmitted in a burst. |
| BURST GAP | | Measured in μs |
| BURST COUNT | | Number of bursts transmitted. |

| Option | Setting | |
|-----------------------|---------------|---|
| RATE | TXGAP | Inter-Packet Gap At 10Gbps, RATE VAL defines the number of bytes added to the 12-byte minimum IPG. At 40Gbps, RATE VAL defined the number of 8-byte words added to the 12-byte minimum IPG. |
| | PACKET/SECOND | Packets transmitted per second |
| | %RATE | Percentage of maximum packet rate. |
| RATE VAL | | Value of the RATE setting. <div style="border: 1px solid #f0e68c; padding: 5px; background-color: #fff9c4;">  The RATE VAL will remain the same value if the RATE changes, which can lead to unexpected results. Eg changing from an TXGAP of 0 (max rate) to %RATE will stop the stream. </div> |
| SIZE | FIXED | Transmit packets of a single packet length only |
| | INCREMENT | Transmit packets with incrementing packet length, starting with SIZE MIN to SIZE MAX , wrapping to SIZE MIN . |
| | DECREMENT | Transmit packets with decrementing packet length, starting with SIZE MAX to SIZE MIN , wrapping to SIZE MAX . |
| | RANDOM | Transmit packets with random packet length between SIZE MAX and SIZE MIN |
| SIZE FIXED/MIN | | Packet Length if SIZE is FIXED. Minimum packet length for variable SIZE modes. <div style="border: 1px solid #90caf9; padding: 5px; background-color: #e1f5fe;">  The minimum allowable packet length at 10Gbps is 13 bytes. The minimum allowable packet length at 40Gbps is 37 bytes. The minimum valid packet length is 64 bytes. </div> <div style="border: 1px solid #f0e68c; padding: 5px; background-color: #fff9c4;">  At 10Mbps, the packet size must be less than 1600 bytes </div> |
| SIZE MAX | | Maximum packet length for variable SIZE modes. Not used if SIZE is FIXED. <div style="border: 1px solid #90caf9; padding: 5px; background-color: #e1f5fe;">  The maximum packet length at 10Gbps and 40Gbps is 16000 bytes. </div> |

6.5.2 Header Configuration

The packet headers and contents are configured in the Header Configuration Panel.



The available headers are extracted from an external configuration file when the APG Control Interface starts. Header support is defined in the APG Header Guide [3].

Headers can be added or deleted:

| Status | Description |
|--------|---|
| | Insert Header. The 'next header' option depends on the previous header eg: ETHERNET_II or VLAN headers can follow a MAC Header. |
| | Delete Header |

Editable fields are identified by a white editing box, and allow user values to be entered.




Fixed fields are greyed out, and cannot be changed.

Variable fields can be FIXED or INCREMENTING. A fixed field uses the field setting only. Incrementing fields operate at byte level, not across the whole field. The **incr** value defines the **step**, and max defines the maximum value.

6.5.3 Payload Configuration








| Option | Setting | |
|--|---|--|
| MODE | FIXED | Fixed, repeating DATA pattern |
| | INCREMENT | Incrementing data byte, starting from the DATA byte, wrapping from 0xFF to 0, repeating to the end of the payload field. |
| | DECREMENT | Decrementing data byte, starting from the DATA byte, wrapping from 0 to 0xFF, repeating to the end of the payload field. |
| | RANDOM | Random byte generator |
| DATA | 8 bytes (hex) eg: 00 11 22 33 44 55 66 77 Repeated to the end of the payload field | |
| A DATA setting shorter than 8 bytes is extended to 8 bytes with 00hex | | |
| OPTIONS | TIMESTAMP | Insert Timestamp checkbox |

6.5.4 Apply/Refresh

| Option | Action |
|---|---|
|  | Applies the configuration to the unit. |
|  | The button is highlighted orange when a configuration change has been made but not applied. |
|  | Refresh cancels the configuration changes and reloads the configuration from the unit. |

6.6 CONTROL PANEL



| Button | Action |
|---|--|
|  | START – Start transmitting on the <u>selected</u> ports. If the unit is in synchronisation mode, all selected ports on the synchronised units will start transmitting simultaneously. |
|  | STEP – Transmit a single packet on the <u>selected</u> ports |
|  | PAUSE – Pause transmission on the <u>selected</u> ports. If the stream is configured to transmit a fixed length burst, the transmit count is paused. Pressing the START button will continue the transmit burst. |
|  | STOP – Stop transmission on the <u>selected</u> ports. |
|  | CLEAR SELECTED COUNTERS – Clear counters on the <u>selected</u> ports only. |
|  | CLEAR <u>ALL</u> COUNTERS |
|  | RESET TIMESTAMPS – Reset timestamps to zero or current time (Section 6.3.5.2) |



To transmit a stream, the port, module and stream must be enabled and the BURST LENGTH must be non-zero or continuous.



If all enabled streams configured on a port are in SINGLE BURST mode and have finished sending packets, the packet transmission automatically stops. Pressing **START** will load the stream configurations into the selected ports before starting transmission.

If the port is transmitting packets, the **STOP** button must be pressed before the **START** to load the stream configurations into the selected ports.

6.7 COUNTER PANEL

The Counter Panel provides access to:

- Port control group selection
- Port selection for Stream Configuration and Status Window
- Hide Port display
- Link Speed and Status display
- Port transmit and receive counters and rates
- Port Options Menu

The Counter Panel is configured using the Edit – Counter Configuration menu (Section 6.3.7), or by right-clicking in the Counter Panel, then selecting 'Counter Configuration'.

The diagram illustrates the Counter Panel interface. At the top, three port selection buttons are shown: 'n1:XPGE2-1.0' (selected with a yellow dot), 'n1:XPGE2-2.0' (unselected with a grey dot), and 'n1:XPGE2-3.0' (unselected with a grey dot). Arrows point to these buttons with labels: 'Port Selected' (pointing to the yellow dot), 'Port Label' (pointing to the port names), and 'Port Not Selected' (pointing to the grey dots). Below the buttons is a table of metrics for each port. The first column lists metrics, and the next three columns show values for ports 1, 2, and 3. The first three rows (Speed, Link, TxPackets) are grouped under 'Link Status'. The next four rows (RxPackets, TxBytes, RxBytes, FCS) are grouped under 'Port Counters'. The next four rows (TxTime, %FCS/RxPkts, Tx rate, Tx PPS) are grouped under 'Transmit Time Calculated Values'. The final seven rows (Rx rate, Rx PPS, Rx64, Rx65-128, Rx129-256, Rx257-512, Rx513-1024, Rx1025-1536, Rx1537-9000, Rx >9000) are grouped under 'Port Counters'. To the right of the table, three mouse icons are shown under the heading 'Mouse Click'. Below them are three vertical panels: 'Toggle port selection' (with a mouse clicking the port label), 'Select Port for Stream Config' (with a mouse clicking the selected port), 'Open Port Status Window' (with a mouse clicking the unselected port), and 'Display Port Options Menu' (with a mouse clicking the unselected port). A 'Port options' menu is shown below the third panel, listing: Hide, Unit control, Port control, Capture buffer, Counter configuration, and Unit Sync.

| | n1:XPGE2-1.0 | n1:XPGE2-2.0 | n1:XPGE2-3.0 |
|-------------|----------------|--------------|--------------|
| Speed | 10Gbps | 10Gbps | 10Gbps |
| Link | UP | PRBS | DOWN |
| TxPackets | 37551932146 | 0 | 0 |
| RxPackets | 36290517236 | 0 | 0 |
| TxBytes | 68144008792413 | 0 | 0 |
| RxBytes | 66057711709442 | 0 | 0 |
| FCS | 0 | 0 | 0 |
| TxTime | 34:10 | 0:00 | 0:00 |
| %FCS/RxPkts | 0.000000 | | |
| Tx rate | 9.600000G | 0.00M | 0.00M |
| Tx PPS | 14285714 | 0 | 0 |
| Rx rate | 9.26896G | 0.00M | 0.00M |
| Rx PPS | 13793102 | 0 | 0 |
| Rx64 | 2515888173 | 0 | 0 |
| Rx65-128 | 32190889 | 0 | 0 |
| Rx129-256 | 64383300 | 0 | 0 |
| Rx257-512 | 128751042 | 0 | 0 |
| Rx513-1024 | 257558479 | 0 | 0 |
| Rx1025-1536 | 257537392 | 0 | 0 |
| Rx1537-9000 | 3754678619 | 0 | 0 |
| Rx >9000 | 3509725578 | 0 | 0 |

| Option | Setting |
|-------------------|--|
| Port Selector | <input checked="" type="radio"/> Port selected for transmit control |
| | <input type="radio"/> Port not selected for transmit control Click on the Port Label toggles the port selection |
| Speed | 1Gbps, 2.5Gbps, 5Gbps, 10Gbps or 40Gbps 10Mbps, 100Mbps with 1000Base-T SFP Transceiver |
| Link Status | Link is UP or DOWN, or the port is in PRBS mode. If TRANSMIT ENABLE (Section 6.10.1.1) is not set (ie module disabled), the Link Status is followed by (txd) PRBS is displayed if the port is in PRBS mode (Section 6.10.4) and the port counters are greyed out. |
| Port Counters | Displays the port transmit, receive and error counters. Use Edit – Counter Configuration to select the displayed counters (Section 6.3.7) |
| Calculated Values | Displays the calculated rate values Use Edit – Counter Configuration to select the displayed calculated values (Section 6.3.7) |

6.8 PORT OPTIONS MENU

Right-clicking in the counter pane opens the Port Options menu:

| Option | Function |
|------------------------------|--|
| Hide | Hides the current port counters. Hidden port counters can be displayed by opening the port expander in the Connection Panel (Section 6.4) and selecting the hidden port checkbox. |
| Unit Control | Opens the Unit Control window (Section 6.9) |
| Port Control | Opens the Port Status window (Section 6.10) |
| Capture Buffer | Opens the Capture Buffer window (Section 6.10.3) |
| Counter Configuration | Opens the Counter Configuration window (Section 6.3.7) |
| Unit Sync | Toggles the synchronisation mode on the unit. All ports on 'sync enabled' units are highlighted gold. |

| Sync Mode Enabled | | | Sync Mode not enabled | |
|---|---|---|---------------------------------|---------------------------------|
| <input checked="" type="radio"/> n1:XP2-6.0 | <input checked="" type="radio"/> n1:XP2-7.0 | <input checked="" type="radio"/> n1:XP2-8.0 | <input type="radio"/> n3:apg1.0 | <input type="radio"/> n3:apg2.0 |
| 10Gbps | 10Gbps | 10Gbps | 10Gbps | 10Gbps |
| UP | UP | UP | UP | UP |
| 11064874530 | 11182680674 | 11302849304 | 0 | 0 |
| 10441969804 | 0 | 0 | 0 | 0 |
| 8730237100284 | 8823123344730 | 8918001015498 | 0 | 0 |
| 8238683150929 | 0 | 0 | 0 | 0 |
| 0 | 0 | 0 | 0 | 0 |
| 131:23 | 131:23 | 131:23 | 0:00 | 0:00 |

A Synchronisation Group contains two or more units in sync-enabled mode. Timestamp and transmit synchronisation functions will only operate on a Synchronisation group.



The APG Control Interface only supports one Synchronisation Group.

6.9 UNIT CONTROL WINDOW (APGV2 UNITS ONLY)

The Unit Control window can be accessed only from the Port Options Menu.

The Unit Control window provides access to:


- Clock Configuration
- Synchronisation Control



Unit Control functions are not supported on APGV1 units.

6.9.1 Unit Clock Tab

The Unit Clock tab allows configuration of the input and output clocks, using the CLOCK-IN and CLOCK-OUT interfaces on the rear panel (Sections 3.3 and 5.6.1)



6.9.1.1 Unit Selector

The Unit Selector shows the connected units capable of supporting Unit Clock Modes. The required unit must be selected before changing the clock configuration.

6.9.1.2 Clock Source

The clock source options are:

| Option | Function |
|----------------------|---|
| Internal | Use the internal free-running oscillator to generate the system clocks (default). Internal mode must be selected if using an Axtrinet unit as the clock master. |
| External 1PPS | Synchronise to an external 1PPS (1Hz) input on the CLOCK-IN interface. |
| External 1MHz | Synchronise to an external 1MHz input on the CLOCK-IN interface. |



For improved clock stability, External 1MHz mode is recommended over External 1PPS mode.

6.9.1.3 External Clock Output

The external clock output options are:




| Option | Function |
|-------------|--|
| 1PPS | Generate a 1PPS (1Hz) output on the CLOCK-OUT interface. |
| 1MHz | Generate a 1MHz output on the CLOCK-OUT interface. |



If using an Axtrinet unit as the clock master, the external clock output frequency (eg External 1MHz) must match the internal clock source (eg 1MHz).


6.9.1.4 Status

The clock status displays the current state of the internal system clock generator:

| State | Description |
|------------------|---|
| UNKNOWN | Unable to determine status |
| INTERNAL | INTERNAL clock source selected |
| HOLDOVER | EXTERNAL clock source selected – external source not detected |
| |  If it remains in this state for more than a few seconds, the external clock source may have failed, not be generating a clock, may be at the wrong frequency, or may not be connected. |
| ACQUIRING | EXTERNAL clock source selected – external clock source detected and attempting to acquire lock. |
| |  Acquisition can take up to 40 seconds with a 1PPS input. Acquisition is <100ms with a 1MHz input. |
| TRACKING | EXTERNAL clock source selected – acquired external clock and improving clock stability. |
| |  Tracking may take up to 90 seconds with a 1PPS input. Acquisition is < 2 seconds with a 1MHz input. |
| LOCKED | EXTERNAL clock source selected – internal clocks frequency-locked to the input clock. It will remain in the LOCKED state until the external clock fails, where it will enter the HOLDOVER state. |

6.9.2 Sync Control Tab


The Sync Control tab allows configuration of the unit synchronisation mode of the connected units. Unit Synchronisation mode must be enabled to enable the inter-unit timestamp and transmit synchronisation functions, using the SYNC interfaces on the rear panel (Sections 3.2.3, 5.6.2 and 5.6.3).




6.9.2.1 Sync Mode


The Sync Mode drop-down list offers the following options:


| Mode | Description |
|----------------------|--|
| AUTOMATIC | The APG Control Interface automatically selects the master unit based on the Synchronisation Group and the ports selected for control. |
| SELECT MASTER | Manually select the Synchronisation Group master unit using the 'master' radio button. |



EXTERNAL Configure the Synchronisation Group to expect an external synchronisation signal **after** pressing the START or RESET TIMESTAMP buttons.

 **The Synchronisation Group enters an 'armed' state, then waits for the external synchronisation trigger. The units will not respond to another command until the trigger is received, the armed state is reset with the Sync Reset button, or the units are removed from the Synchronisation Group. Attempting to control the units while in the 'armed' state will generate a pop-up 'busy' warning message:**





6.9.2.2 Connected Units

Lists the connected units and the sync capability.

Only sync-capable units can be enabled.

6.9.2.3 Sync Configuration

Enable/Disable unit synchronisation mode on each connected unit to add/remove the unit from the Synchronisation Group.

If operating in 'Select Master' mode, the 'Master' radio buttons are enabled.

6.9.2.4 Sync Reset

Clears the 'armed' state from the Synchronisation Group.

6.10 PORT STATUS WINDOW


The Port Status window can be accessed in two ways:

- Right-click in the counter pane to open the Port Menu, then select "Port Control", or
- Middle-click in the counter pane

The Port Status window provides access to:

- Module control and status signals
- Module information
- Packet Capture Summary (all ports)
- PRBS Bit Error Rate testing (all ports)

6.10.1 Control Tab



The content of the Control Tab varies depending on the inserted module.

6.10.1.1 Module Control & Status

The Module Control bits can be set by the user:

| Option | Function |
|------------------------|--|
| Transmit Enable | Set to enable the transceiver If not set (ie module disabled), the Link Status in the counter panel (Section 6.7) is followed by (txd) |
| Rate Select 1/0 | Rate Select bits are normally set for 10Gbps operation, but the actual behaviour is defined by the transceiver vendor. |

The Module Status bits are read-only, and set by the transceiver:

| Status | Definition |
|----------------|------------------------------|
| Present | Transceiver detected in port |
| LOS | "Loss of Signal" flag |
| Fault | "Fault" flag |

Where: ● Set ● Not Set ● Not Available

The Link Status bits are set by the transceiver:

| Status | Definition |
|--------------------|---|
| Local Link | Displays the link status of the Packet Generator MAC to the link partner. For fibre optic and direct attach cables, this is the end-to-end link status. Where the module contains an additional active linking device, eg the 10Gbase-T and 10/100/1000Base-T modules contain a PHY, the 'Local Link' is the MAC-to-PHY link status. |
| Module Link | For fibre optic and direct attach cables, the 'Module Link' is not available. Where the module contains an additional active linking device, eg the 10Gbase-T and 10/100/1000Base-T modules contain a PHY, the 'Module Link' is the external link status to the link partner. |

6.10.1.2 Physical Configuration

Port Topology and Connection Mode are configured in the Physical Configuration settings to the applicable port.

6.10.1.3 Module Configuration (optional)


The Control Tab will display additional module configuration options if they are available, eg for the 2.5G/5G/10Gbase-T modules:



The 2.5G/5G/10Gbase-T and 10/100/1000Base-T Configuration comprises the Auto-Negotiation and Advertised Capabilities settings, the partner capabilities, and MDI/MDIX and Master/Slave configuration.


6.10.2 Module Tab

The Module tab shows the raw and decoded vendor fields from the inserted module.



6.10.3 Capture Tab

The capture tab displays a summary of the capture buffer configuration, status and control for **all** available ports.



The capture configuration shows the ENABLE and DEEP setting for each port.



On an APGV1 unit, Deep Capture can only be enabled on one port.


The status values show the data captured in bytes (available), buffer space allocated in bytes (alloc) and upload progress (yellow bar and %).

The port capture buffers can be controlled with the buttons:

| Control | Function |
|---------|---|
| | Clear the packet capture buffer and restart the capture. |
| | Click the VIEW button to display the captured packets. |
| | Upload the Packet Data window with the latest captured data. |
| | Updating the Packet Data window without clearing the packet capture buffer will reload the same captured packet data. |
| | Stop the port capture |
| | View the uploaded data in the Capture Data Display window (Section 6.11) |
| | Save the captured port data to a PCAP file. |
| | Uploads all captured port data. |

6.10.4 PRBS Tab

The PRBS tab displays a summary of the PRBS configuration, status and control for **all** available ports.



| Status | Definition |
|---|--|
| Mode | Dropdown PRBS pattern for each port. The options are: PRBS7 $(x^7 + x^6 + 1)$ PRBS9 $(x^9 + x^5 + 1)$ PRBS15 $(x^{15} + x^{14} + 1)$ PRBS23 $(x^{23} + x^{18} + 1)$ PRBS31 $(x^{31} + x^{28} + 1)$ |
| TXEN / RXEN | Separate Transmit and Receive enables: <input type="checkbox"/> Disabled <input checked="" type="checkbox"/> Enabled Port PRBS mode is enabled is either is set. |
| Locked | Receiver synchronised to transmit pattern: <input type="checkbox"/> Not Locked <input checked="" type="checkbox"/> Locked The receiver will report locked after 15 bits have been received without error. It will break lock after $\sim 80\mu s$ if continuous errors are detected. |
| RX Time | Time since first locked |
| RX Error | Number of receive bit errors detected since locked. |
| Rate | Bit Error Rate |
| Clear | Clear the error counter and timer. The Bit Error Rate is a calculated value and will clear automatically. |
| <div style="background-color: #e0e0e0; padding: 5px; border: 1px solid #ccc;"> i Bit errors may be detected as the receiver locks to the transmit bit stream. Clear the errors and timer before starting a test run. </div> | |

6.11 CAPTURE DATA DISPLAY


The Capture Data Display window is accessed either through the Port Status Capture Tab, or by right-clicking in the counter panel to open the Port Menu, then selecting 'Capture Buffer'.

Packet Capture can be enabled per port by selecting the ENABLE checkbox. When enabled, the buffer captures continuously until full. Clearing the buffer deletes the captured packets, and immediately starts a new capture.

Each port has a 64KB capture buffer to store a few packets (depending on packet length) which is useful for analysing single step behaviour or rare events. Alternatively, access to the 1GB shared extended packet capture can be enabled by selecting the DEEP checkbox, to store large packet streams. The 64KB buffer is disabled when the deep packet capture is enabled.



On an APGV1 unit, Deep Capture can only be enabled on one port.



The buffer control is performed with the following buttons:

| Control | Function |
|---------------------------------------|---|
| <input type="button" value="Upload"/> | Update with the latest captured packet data to the Capture Data Display window. The UPLOAD STATUS bar displays the Buffer Status (% used), and the upload progress (% uploaded). |
| <input type="button" value="Save"/> | Saves the captured data to PCAP file. Opens a FILE SAVE window to select save directory and filename. |
| <input type="button" value="Clear"/> | Clear the packet capture buffer and restart the capture. |



Click 'UPLOAD' button to display the captured packets.

The display window shows the 'Captured Packet Number', the transmit timestamp, the packet data (showing 'Display Packet Width' bytes), and packet length.

6.12 SLIDERS

Vertical and horizontal slider allows adjustment of the panel sizes to suit viewing requirements.



Xentech Solutions Ltd
Suite 6 Stanta Business Centre
3 Soothouse Spring
St Albans
AL3 6PF
United Kingdom

Tel: +44 (0)1727 867795
Email: support@axtrinet.com